



Stanislaus Consolidated Fire Protection District
3324 Topeka Street
Riverbank, California 95367
Phone (209) 869-7470
Fax (209) 869-7475

January 15, 2008

Todd Troglin
Turlock Irrigation District
333 E. Canal Drive
Turlock, CA 95381

Dear Mr. Troglin:

As discussed at our last meeting, the following is documentation regarding the last fire flow test conducted by the Stanislaus Consolidated Fire Protection District for the Community of La Grange.

The fire flow test was conducted across from the La Grange Elementary School, 30237 Floto Street in La Grange for compliance with the 2001 California Fire Code Appendix III-A & III-AA of the California Code of Regulations, Title 24, Part 9.

The test was conducted on May 29, 2007. The test did not meet minimum Fire Code requirements.

Due to fire and life safety concerns the lack of adequate fire flow poses, it is requested that the District take such steps as are immediately possible to increase the fire flow to meet Title 19 and 24 of the California Code of Regulations.

If you have any questions, please feel free to call me at 869-7470.

Sincerely,

A handwritten signature in black ink, appearing to read "S. Mayotte", with a long, sweeping horizontal line extending to the right.

Stephen Mayotte
Fire Chief